



Certificate of Compliance

This certificate is issued for the following equipment:

Model	Nominal K-Factor	Nominal Spray Angle (Degrees)	Nominal Thread Size (in.)	Finishes
Tankcool	1.74 gal/min/(psi) ^{1/2} (25 L/min/(bar) ^{1/2})	150	1/2	Brass, Stainless Steel
Tankcool	2.02 gal/min/(psi) ^{1/2} (29 L/min/(bar) ^{1/2})	150	1/2	Brass, Stainless Steel
Tankcool	3.13 gal/min/(psi) ^{1/2} (45 L/min/(bar) ^{1/2})	150	1/2	Brass, Stainless Steel
Tankcool	3.34 gal/min/(psi) ^{1/2} (48 L/min/(bar) ^{1/2})	150	1/2	Brass, Stainless Steel

Prepared for: GW Sprinkler A/S, Kastanievej 15, DK-5620 Glamsbjerg, Denmark

Manufacturing Location: GW Sprinkler A/S, Kastanievej 15, DK-5620 Glamsbjerg, Denmark

FM Approvals Class: 2025

FM Approval Standard: Class 2021/2025 (February 2010)

Approval Identification: 3051090

Approval Granted: January 31, 2014

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne'.

Richard B. Dunne
Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Model	Nominal K-Factor	Nominal Spray Angle (Degrees)	Nominal Thread Size (in.)	Finishes
Tankcool	4.14 gal/min/(psi) ^{1/2} (60 L/min/(bar) ^{1/2})	150	1/2	Brass, Stainless Steel
Tankcool	4.82 gal/min/(psi) ^{1/2} (70 L/min/(bar) ^{1/2})	150	1/2	Brass, Stainless Steel
Tankcool	5.31 gal/min/(psi) ^{1/2} (77 L/min/(bar) ^{1/2})	150	1/2	Brass, Stainless Steel
Tankcool	5.86 gal/min/(psi) ^{1/2} (85 L/min/(bar) ^{1/2})	150	1/2	Brass, Stainless Steel

Prepared for: GW Sprinkler A/S, Kastanievej 15, DK-5620 Glamsbjerg, Denmark

Manufacturing Location: GW Sprinkler A/S, Kastanievej 15, DK-5620 Glamsbjerg, Denmark

FM Approvals Class: 2025

FM Approval Standard: Class 2021/2025 (February 2010)

Approval Identification: 3051090

Approval Granted: January 31, 2014

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "Richard B. Dunne", is written over a horizontal line.

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group